

RESOLUTION NO. 36-2023

Introduced by Matt Grieves

A RESOLUTION AUTHORIZING THE CITY MANAGER TO ENTER INTO AN AGREEMENT WITH LAKE ERIE DIVING, INC. FOR HURON WATER TREATMENT PLANT RAW WATER INTAKE CLEANING IN AN AMOUNT NOT TO EXCEED TWO HUNDRED SEVENTY-SIX THOUSAND ONE HUNDRED EIGHTY-THREE AND 00/100 DOLLARS (\$276,183.00)

BE IT RESOLVED BY THE COUNCIL OF THE CITY OF HURON, OHIO:

SECTION 1: That the City Manager is authorized and directed to enter into an agreement with Lake Erie Diving, Inc. For Huron Water Treatment Plant raw water intake cleaning in an amount not to exceed Two Hundred Seventy-Six Thousand One Hundred Eighty-Three and 00/100 Dollars (\$276,183.00); a copy of the agreement is attached hereto as Exhibit "A" and incorporated herein by reference.

SECTION 2: That this Council hereby finds and determines that all formal actions relative to the adoption of this Resolution were taken in an open meeting of the Council and that all deliberations of this Council and of its committees, if any, which resulted in formal action, were taken in meetings open to the public in full compliance with applicable legal requirements, including O.R.C. §121.22 of the Revised Code.

SECTION 3: This Resolution shall be in full force and effect from and immediately following its adoption.


ATTEST:


Clerk of Council


Monty Tapp, Mayor

ADOPTED:

25 APR 2023



LAKE ERIE DIVING, INC.

Professional Diving & ROV Services

7 April 2023

City of Huron
Water Treatment Plant
10 Waterworks Dr
Huron, OH

Attn: Mr. Jack Evans

Re: Raw Water Intake Cleaning

Mr. Evans,

Our quote to clean the 36" raw water intake pipe a distance of approximately 2,300' is as follows:

- Mob/Demob from Painesville, Ohio.
- Remove and dispose of two existing chemical feed lines.
- Remove existing water door air lines.
- Remove all sediment from approximately 2,300' of 36" raw water intake pipe.
Huron to furnish a 6" trash pump and hose. Pump to be fueled daily by the city.
Place water and mud in the adjacent shoreline rip rap as it is removed from the pipe.
- Upon completion of the cleaning the entire 36" intake pipe will be inspected with an ROV to document the pipe is clean.
- Furnish two 1 1/4" HDPE chemical feed lines and strength member.
- Band HDPE chemical feed lines and strength member every 25' with stainless steel banding.
- Install and secure at the crib the new chemical feed line.
- Install the removed air lines for the water door.
- Clean raw well upon completion of the pipe cleaning.

Liability, automobile, and workers compensation certificates will be furnished upon request.
I would like to do the project in early summer if possible.

LUMP SUM QUOTE: \$276,183.00

If you have any questions in regards to the above, please contact me on my cell at (216) 299-1396.

Respectfully,

Patrick M. Murphy
President