

RESOLUTION NO. 60-2023

Introduced by Matt Grieves

A RESOLUTION AUTHORIZING THE CITY MANAGER TO ACCEPT THE PROPOSAL AND ENTER INTO AN AGREEMENT WITH R.A. BORES EXCAVATING, INC. FOR REPLACEMENT OF A WATER MAIN DAMAGED IN A VEHICLE ACCIDENT ON SAWMILL PARKWAY IN AN AMOUNT NOT TO EXCEED ONE HUNDRED FIVE THOUSAND EIGHT HUNDRED SEVENTY-SIX AND XX/100 DOLLARS (\$105,876.00).

WHEREAS, an emergency water main repair is required on Sawmill Parkway as a result of a semitruck colliding with a fire hydrant on May 30, 2023, causing the water main to break; and

WHEREAS, the repair includes replacement of 153' of 12" ductile iron watermain with PVC, and the line must be directionally bored under the creek near the culvert.


NOW, THEREFORE, BE IT RESOLVED BY THE COUNCIL OF THE CITY OF HURON, OHIO:

SECTION 1. That the City Manager shall be, and he hereby is, authorized and directed to accept the proposal and enter into an agreement with R.A. Bores Excavating Inc. For water main replacement on Sawmill Parkway in an amount not to exceed One Hundred Five Thousand Eight Hundred Seventy-Six and 00/100 Dollars (\$105,876.00, which agreement shall be in substantially in the form of Exhibit "A" attached hereto and made a part hereof.

SECTION 2. That this Council hereby finds and determines that all formal actions relative to the adoption of this Resolution were taken in an open meeting of this Council and that all deliberations of this Council and of its Committees, if any, which resulted in formal action, were taken in meetings open to the public in full compliance with applicable legal requirements, including O.R.C. §121.22.


SECTION 3. That this Resolution shall be in full force and effect from and immediately after its adoption.

ATTEST:


Clerk of Council

ADOPTED:

22 AUG 2023


Mark Claus, Vice-Mayor





R. A. Bores
 Excavating, Inc.
 2819 Dogtown Rd.
 PO Box 217
 Monroeville, OH 44847

Office: 419-465-4673
 Fax: 419-465-3083
 bob@raboresh.com
 luke@raboresh.com
 vickie@raboresh.com

Quote

Date	Quote #
8/1/2023	1427

An Equal Opportunity Employer

Name / Address
City of Huron Attn: Jack Evans 417 Main St. PO Box 468 Huron, Ohio 44839

Rep	Project

Description	Total
<p>12" Water Line @ Culvert of Sawmill Parkway</p> <p>Revised Quote to perform the following water line work directly with the City Water Dept. Price per L.F. - Original Quote \$785.00 per ft. Revised Quote: \$692.00 per ft.</p> <p>We visited the site late Friday 07-28-23, and met with Terry Oats, from the water department, to determine the scope of work.</p> <ol style="list-style-type: none"> 1. Replace approx. 153 L.F. of 12" D.I.P. with 12" PVC Cert-a-Lok Pipe by directional drill method. 2. Install 2" blow off at each end of the pipe to sample and pressure test prior to connecting to the existing 12" D.I.P. 3. After testing is complete, will make connection to existing 12" D.I.P. using M.J. bends. <p>NOTE: Will invoice for actual amount of pipe installed.</p> <p style="text-align: center;">\$692/ft. X 153 ft. = \$105,876</p>	

Total	\$0.00
--------------	--------